



**ADDENDUM #1**

**City of Commerce**

**REQUEST FOR COMPETITIVE SEALED PROPOSALS**

**For**

**WTP Filter Rehab Project**

**# 20-200-01**

**April 6, 2022**

The contract documents will be modified as follows:

1. The Bid Schedule is attached.
2. Environmental Improvements (EI2) is the vendor for the Leopold Filter Underdrains. Contact Michael Carpenter at 214-436-2536 (office) or 214-907-2269 (cell).
3. The existing filter media may be disposed of on site.
4. For the additive alternate, the painting of the exterior walls of the filters will go down to 6" above the bottom of the filter wall. The bottom of the painting will be taped off to create a smooth finish. The primer shall allow top-coating of the existing paint. The OWNER will select the color.
5. For the deductive alternate, the interior walls of the filter cells will still be sandblasted and primed. However, in lieu of installing a new steel wall inside of each cell, the walls will be painted instead. The top of the concrete filter underdrain support and the walls, sides, and bottom of the gullet will still be lined with the steel liner as originally outlined in the contract documents.

HAYTER ENGINEERING

Michael N. Tibbets, P.E.  
Vice President

**Practical Infrastructure Solutions**

4445 SE Loop 286 | Paris, TX 75460 | haytereng.com  
TxEng F-315 | TxSurv F-10028600 | OSBPE/LS #603 | ASBPE #2521 | LA #EF6529  
Texas | Oklahoma | Arkansas | Louisiana